

## Surface Water Discharge Monitoring

EPL No:	20581
Date of Reported Results	11.03.2019

Pollutant	Unit*	Frequency	Monitoring Point 1		
			07-11-18	28-11-18	20.02.2019
pH	pH	Following discharge event	7.43	7.34	7.86
Total Suspended Solids, TSS	mg/L	Following discharge event	16	<5	9
Nitrogen (ammonia)	mg/L	Following discharge event	0.21	0.11	0.69
Biochemical Oxygen Demand	mg/L	Following discharge event	3	4	<2
Oil & Grease	mg/L	Following discharge event	<5	<5	<5

* Unit of Measure Abbreviations	
Milligrams per Litre	mg/L

\*Sample taken from Humeceptor outlet