

## Feb-19

PO Box 2891  
Taren Point BC NSW 2229

Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Annual Limits		Min.	10%-ile	Median	Average	90%-ile	Max.	Comments/explanation
				10%-ile Limit	90%-ile Limit							
<b>EPL 12904</b>												
<b>Monitoring Point 8</b>												
Conductivity	microsiemens per centimetre	Continuous during discharge	Continuous during discharge	-	-	11,207		49,049	47,128		69,154	
Temperature	Celsius	Continuous during discharge	Continuous during discharge	-	-	18.23		21.48	21.35		25.85	
Salinity	-	Continuous during discharge	Continuous during discharge	-	72	6.82		34.41	33.45	39.28	48.41	
Oxidation Reduction Potential	millivolts	Continuous during discharge	Continuous during discharge	-	-	174.56		254.25	256.44		454.26	
pH	pH	Continuous during discharge	Continuous during discharge	6.5	8.8	7.32	7.71	7.84	7.84	8.00	8.05	
Total dissolved solids	milligrams per litre	Weekly during any discharge	4	-	-	31,600			35,075		37,000	
Total residual chlorine	milligrams per litre	Daily during any discharge	19	-	0.1	0.02			0.02	0.02	0.02	No discharge occurred 02/02/2019, 03/02/2019, 09/02/2019, 10/02/2019, 16/02/2019, 17/02/2019, 23/02/2019, 24/02/2019. Sample pump was not operational on 26/2/19, therefore grab sample was not able to be collected.
Total suspended solids	milligrams per litre	Weekly during any discharge	4	-	30	1.00			1.00	1.00	1.00	
Turbidity	nephelometric turbidity units	Daily during any discharge	19	-	-	0.10			0.31		1.20	No discharge occurred 02/02/2019, 03/02/2019, 09/02/2019, 10/02/2019, 16/02/2019, 17/02/2019, 23/02/2019, 24/02/2019. Sample pump was not operational on 26/2/19

Note: The table above is analysing the monthly data against annual limits. A table that analyses the annual data against the annual limits prescribed above will be published in January of each year.