

**Gerringong Gerroa Sewage Treatment Scheme  
EFFLUENT MONITORING POINT 23**

	BOD (mg/L)	Total Nitrogen (mg/L)	Total Phosphorous (mg/L)	Suspended Solids (mg/L)	Faecal Coliforms (/100mL)	pH	Oil and Grease (mg/L)	Comments
Number of Samples	4	4	4	4	4	4	0	
Minimum Value	1	0.68	0.022	1	0	7.1		
Maximum Value	1	1.22	0.027	1	0	7.2		
Monitoring frequency required by licence	Every 6 days	Every 6 days	Every 6 days	Every 6 days	Every 6 days	Every 6 days	Quarterly	
100 Percentile Limits						6.5 - 9	10	
Limit of Detection (LOD)*	2	0.05	0.002	2	1	0.1	5	

\* Where the laboratory result is below LOD, values are input as half the LOD to allow for statistical analysis, excluding faecal coliform bacteria which is input as zero where < 1

Note : An additional table which summarises the yearly 50th percentile limits will be included to allow comparison with the performance limit.