

Surface Water Discharge Monitoring

EPL No:	20581
Date of Reported Results	26/7/2019

Pollutant	Unit*	Frequency	Monitoring Point 1						
			19/04/2019	19/05/2019	19/06/2019	19/06/2019	19/06/2019	19/06/2019	19/07/2019
pH	pH	Following discharge event	7.79	7.19	7.44	7.39	7.16	7.71	7.36
Total Suspended Solids, TSS	mg/L	Following discharge event	<5	10	10	6	15	<5	<5
Nitrogen (ammonia)	mg/L	Following discharge event	0.36	0.12	0.08	0.03	0.08	0.78	0.92
Biochemical Oxygen Demand	mg/L	Following discharge event	<2	2	6	<2	<2	<2	<2
Oil & Grease	mg/L	Following discharge event	<5	<5	<5	<5	<5	<5	<5

* Unit of Measure Abbreviations	
Milligrams per Litre	mg/L

<https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=116842&SYSUID=1&LICID=20581>