

December 31, 2019

EPL 11797

<https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=70413&SYSUID=1&LICID=11797>

Test date: November 3, 2019  
Date results received: December 19, 2019

POINT 3 – CO-GENERATION EXHAUST STACK

Parameter	Unit of Measure	Frequency	Lower Limit	Averaging Period	Result
Nitrogen Oxides	mg/m <sup>3</sup>	Yearly	450	1-hour	310
Volatile Organic Compounds	mg/m <sup>3</sup>	Yearly	40	1-hour	<0.2
Sulfuric Acid mist and Sulfur Trioxide	g/m <sup>3</sup>	Yearly	0.1	1-hour	0.04