



Dec 2023

VEOLIA WATER OPERATIONS PTY LTD

PO Box 2891

Taren Point BC NSW 2229

Pollutant	Units of measure	Monitoring frequency required by licence	No. of times measured during month	Annual Limits		Min.	10%-ile	Median	Average	90%-ile	Max.	Comments / explanation
				10%-ile Limit	90%-ile Limit							
EPL 12904												
Monitoring Point 8												
Conductivity	microsiemens per centimetre	Continuous during discharge	Continuous during discharge	-	-	54,648	74,038	75,382	75,371	76,566	80,300	
Temperature	celsius	Continuous during discharge	Continuous during discharge	-	-	17.84	18.95	20.28	20.44	22.17	24.35	
Salinity	-	Continuous during discharge	Continuous during discharge	-	72	40.19	55.24	58.19	58.09	60.86	63.47	
Oxidation Reduction Potential	millivolts	Continuous during discharge	Continuous during discharge	-	-	209.96	248.34	304.11	306.73	374.39	398.50	
pH	pH	Continuous during discharge	Continuous during discharge	6.5	8.8	6.97	7.10	7.18	7.17	7.24	7.36	
Total dissolved solids	milligrams per litre	Weekly during any discharge	4	-	-	58,200	58,740	61,050	60,650	62,240	62,300	
Total residual chlorine	milligrams per litre	Daily during any discharge	31	-	0.1	0.04		0.04	0.04	0.04	0.06	
Total suspended solids	milligrams per litre	Weekly during any discharge	4	-	30	2.00		2.60	5.00	5.25	8.10	9.00
Turbidity	nephelometric turbidity units	Daily during any discharge	31	-	-	0.20	0.20	0.20	0.25	0.40	0.60	

Note 1: The table above is analysing the monthly data against annual limits. A table that analyses the annual data against the annual limits prescribed above will be published in January of each year.  
\* : SWDN- Sydney Water Distribution Network

Published: 2024Jan04