

Monthly EPL Report

Gerringong Gerroa Sewerage Scheme

EPL Licence 11317

Units	BOD (mg/L)	Total Nitrogen (mg/L)	Total Phosphorus (mg/L)	Suspended Solids (mg/L)
Compliance limit	<5	<3	<0.1	<3
Number of Samples	4	4	4	4
Minimum	1	0.77	0.017	1
Maximum	1	0.95	0.029	1
Monitoring frequency required by licence	Every 6 days	Every 6 days	Every 6 days	Every 6 days
100 Percentile Limits				
Limits of Detection (LoD)*	2	0.05	0.002	2

NOTES

BOD - Biochemical Oxygen Demand

* Where the laboratory result is below L analysis, excluding faecal coliform baci

Sydney Water Corporation

From 01/Feb/2024
To 29/Feb/2024

Effluent Monitoring Point 23

Faecal Coliforms (/100mL)	pH pH	Oil & Grease (mg/L)
<2		
4	4	0
0	7.20	
0	7.30	
Every 6 days	Every 6 days	Quarterly
	6.5 - 9	10
1	0.1	5



.oD, values are input as half the LoD to allow for statistical
teria which is input as zero where < 1

